



Gardner Architects

Addendum #5 (revised - see bold italic type)

January 4, 2010

Renovations to:
7991 Columbus Pike
Lewis Center, Ohio 43035

ADDENDUM #5:

This Addendum, hereby modifies, supplements and amends the original Specifications and Drawings for all material, labor and equipment of every nature necessary for the execution of the entire work Renovations to: 7991 Columbus Pike, Lewis Center, Ohio 43035, as prepared by Gardner Architects, dated in the Title Block: 12.1.2009. Wherein this Addendum varies or is in conflict with the Specifications or Drawings, the requirements of this Addendum shall govern, in all other particulars the requirements of the original Specifications and Drawings, dated December 1, 2009, shall govern.

Specification Items

Item #1: DIVISION 6

Section 062000 - Finish Carpentry, Part 2 Products, Paragraph 2.2, A, 1. Products:
Add Versatex by Wolfpac Technologies, Inc., to the product manufacturers listed as acceptable manufacturers.

Drawing Items

Item #2: SHEET 9 OF 13, NOTE 6

At the end of Note 6 which reads, "BUILDING ELECTRICAL CONTRACTOR TO PROVIDE CIRCUIT WITHIN BUILDING", add, "WIRING FROM CONTACT ENCLOSURE LC-1 TO SITE LIGHTING AND SIGNAGE FIXTURES, INCLUDING SITE LIGHTING AND SIGNAGE FIXTURES, TO BE PROVIDED BY BUILDING GENERAL TRADES CONTRACTOR."

Item #3: SHEET H3.0B, DETAIL 3

Heat Pumps HP-31 and HP-32 are presently shown as work included in HVAC Base Bid "B". Include all HVAC work associated with Heat Pumps HP-31 and HP-32 in HVAC ***Alt. #1B***.

Item #4: SHEET E2.0B, DETAIL 3

There are two HP-25 heat pumps shown. The one adjacent to HP-27 should read HP-32.

Heat Pumps HP-31 and HP-32 are presently shown as work included in Elec. Base Bid "B". Include all electrical work associated with Heat Pumps HP-31 and HP-32 in Elec. ***Alt. #1B***.

END OF ADDENDUM #5

