

ADDENDUM NO. 2

GRANDSTAND RESTROOMS – HAYES HIGH SCHOOL STADIUM

Project No. 208047.02


Index of Contents

Addendum No. 2, 2 items, 1 page
Information Available to Bidders – Pre-Bid Meeting Sign-In Sheet

February 17, 2010

I hereby certify that this Addendum was prepared by me or under my direct supervision and that I am a duly registered Architect/Engineer under the Laws of the State of Ohio.

FANNING/HOWEY ASSOCIATES, INC.
ARCHITECTS/ENGINEERS/CONSULTANTS



TO: ALL BIDDERS OF RECORD

ADDENDUM NO. 2 to Drawings and Project Manual, dated February 8, 2010 for Grandstand Restrooms – Hayes High School Stadium for the Delaware City School District, 248 N. Washington St., Delaware, Ohio, 43015; as prepared by Fanning/Howey Associates, Inc., Dublin Ohio.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes, and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

Each bidder shall acknowledge receipt of this Addendum in his proposal or bid.

NOTE: Bidders are responsible for becoming familiar with every item of this Addendum. (This includes miscellaneous items at the very end of this Addendum.)

RE: ALL BIDDERS

ITEM NO. 1. DRAWING SHEET G3.1 – DETAILS AND SECTIONS

A. Details 1, 7 and 9: revise the "Glasgrid" note to read as follows:

"GLASGRID DETAIL REPAIR SYSTEM, TYPE 8502, MANUFACTURED BY SAINT-GOBAIN TECHNICAL FABRICS, SUPPLIED BY CONTECH CONSTRUCTION PRODUCTS, INCORPORATED (614-846-2343)

ITEM NO. 2. DRAWING SHEET M2.1 – VENTILATION PLAN

A. Add Ventilation Plan Note 8 in Mechanical Room 102 as follows: "CONTRACTOR TO PROVIDE 6" FLUE FROM AHU TO ROOF. THE FLUE SHALL BE B-VENT. ROUTE FLUE THROUGH ROOF WITH A THIMBLE AND TERMINATE A MINIMUM OF 36" ABOVE ROOF WITH A RAIN CAP. SUPPORT THE FLUE FROM BUILDING STRUCTURE."

B. Add the following to Mechanical Specification Note 3.b.: "CONTRACTOR IS RESPONSIBLE FOR ALL TESTING AND BALANCING OF SYSTEM."

C. Revise Mechanical Specification Note 3.c. as follows: "CONTRACTOR TO INCLUDE A \$3,500.00 ALLOWANCE FOR COMMISSIONING REPORT FROM ADVANCED BUILDING TECHNOLOGIES. ONCE UNIT IS INSTALLED AND TESTED, CONTRACTOR TO CONTACT OWNER TO SCHEDULE COMMISSIONING. ANY CHANGES OR MODIFICATIONS TO SATISFY COMMISSIONING REPORT ARE THE RESPONSIBILITY OF THE CONTRACTOR."

D. Add Mechanical Specification Note 6.a.8 as follows: "RETURN AIR AND OUTSIDE AIR DAMPERS ARE TO BE PROVIDED BY THE UNIT MANUFACTURER."

PROJECT – GRANDSTAND RESTROOMS
HAYES H.S. STADIUM
DELAWARE CITY SCHOOLS

SIGN-IN SHEET

<u>COMPANY NAME</u>	<u>PERSON ATTENDING</u>	<u>CONTACT INFORMATION</u> <u>Telephone, Fax & E-mail</u>
Delaware City Schools	Larry Davis	Ph: 740-833-1120 Fx: 740-833-1149 davisla@dcs.k12.oh.us
Delaware City Schools	George Harmon	Ph: 740-833-1865 Fx: 740-833-1898 George_harmon@dcs.k12.oh.us
Speer Mechanical	Brent Skatzes	614-261-5187 bskatzes@speermechanical.com
Fanning Howey	Clair Howey	614-764-4661 chowey@fhai.com
Hensel Ready Mix	Errol VanDyck	800-985-4515 Cell: 740-225-5714 errol@henselreadymix.com
Lang Masonry & GC	Tom Kern	740-749-3512 Fx: 740-749-3500 tkern@langmasonry.com
Mast Electric	Scott Mast	740-694-8802 Fx: 740-694-8822 Brayman4@yahoo.com
Scioto Mechanical	Charlie Kuder	614-276-5580 Fx: 614-276-5581 sciotomech@sbcglobal.net
Elford, Inc.	Jason Brown	614-488-4000 Fx: 614-487-6602 jtb@elford.com
R W Setterlin Building Co.	Mark Setterlin	614-459-7077 Fx: 614-545-5844 m.setterlin@setterlin.com
Simco Electric	Keye Simpkins	740-363-8362 Fx: 740-369-2269 keye@simcoelec.com
Fanning & Howey	Cliff Brady	419-586-7771 cbrady@fhai.com
Gutknecht Construction	Mark Montee	614-532-5410 Fx: 614-532-5415 c.fish@gutknecht.com
Gaylor Inc.	Eric Wilkerson	614-761-9304 Fx: 614-761-9305 ewilkerson@gaylor.com

PROJECT – GRANDSTAND RESTROOMS
HAYES H.S. STADIUM
DELAWARE CITY SCHOOLS

SIGN-IN SHEET

<u>COMPANY NAME</u>	<u>PERSON ATTENDING</u>	<u>CONTACT INFORMATION</u> <u>Telephone, Fax & E-mail</u>
C & N Industrial Contractors Inc.	Matt Perkins	937-322-7341 937-325-7738 mperkins@cn-industrial.com
Axis Construction	Joel Kingsley	614-834-8377 Fx: 614-833-4195 joel@axisconstructionllc.com